

TECHNICAL BULLETIN

No: TB07 Revised November 15, 2021

Certificate of Compliance Aerocel® EPDM Closed Cell Elastomeric Foam Insulation

MANUFACTURING SPECIFICATIONS

- ASTM C534 Grade 1, Type I (tubular) and Type II (sheet) Standard Specification for Preformed Flexible Elastomeric Cellular Thermal Insulation in Sheet and Tubular Form -Result: meets requirements
- ASTM D1056, 2C1 Standard Specification for Flexible Cellular Materials Sponge or Expanded Rubber - Result: meets requirements
- ASTM D1171 Standard Test Method for Rubber Deterioration Surface Ozone Cracking Outdoors Result: no cracking
- ASTM G7 Standard Practice for Atmospheric Environmental Exposure Testing of Nonmetallic Materials Result: minimal cracking or color change

FIRE BEHAVIOR

- ASTM E84 (25/50 Flame Spread/Smoke Developed Index) Standard Test Method for Surface Burning Characteristics of Building Materials Result: pass (up to 2" or 50 mm thick)
- ASTM D635 Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizonal Position - Result: self-extinguishing
- NFPA 90A Standard for the Installation of Air-Conditioning and Ventilating Systems Result: meets requirements (up to 2" or 50 mm thick)
- NFPA 90B Standard for the Installation of Warm Air Heating and Air-Conditioning Systems Result: meets requirements (up to 2" or 50 mm thick)
- **UL94** Tests for Flammability of Plastic Materials for Parts in Devices and Appliances Result: flame classification V-0

CHEMICALS / VOC'S / HUMAN HEALTH

- Health Product Declarations (HPD's) verified per HPDC Open Standard v2.2 Result: Verified
- GREENGUARD / GREENGUARD Gold Certified for low chemical emissions Result: Certified
- California Department of Public Health CDPH Specification 01350 Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers Result: meets requirement
- ASTM C1338 Standard Test Method for Determining Fungi Resistance of Insulation Materials and Facings - Result: no growth (no biocides added)
- ASTM G21 Standard Practice for Determining Resistance of Polymeric Materials to Fungi -Result: no growth (no biocides added)
- **UL181** Standard for Factory-Made Air Ducts and Air Connectors, Section 13 Mold Growth Result: no growth (no biocides added)

- EPA TSCA compliant
- RoHS 3 compliant
- REACH compliant
- PBDE-free
- Nitrosamine-free
- Asbestos-free
- Fiber-free

ENVIRONMENT

- Environmental Product Declarations (EPD's): Product-specific Type III
- No CFC's, HFC's or HCFC's utilized during manufacturing

U.S. GREEN BUILDING COUNCIL (USGBC) LEADERSHIP IN ENERGY AND ENVIRONMENTAL DESIGN (LEED®)

- Energy & Atmosphere (EA)
- Materials & Resources (MR)
 - Product Disclosure & Optimization: Environmental Product Declarations <u>Result: can contribute</u>
 - Product Disclosure & Optimization: Material Ingredients Result: can contribute
- Indoor Environmental Quality (EQ)
 - Prerequisite: Minimum Energy Performance Result: can contribute
 - Credit: Optimize Energy Performance Result: can contribute
 - Credit: Low-Emitting Materials Result: can contribute
 - Credit: Indoor Air Quality Assessment Result: can contribute
 - Credit: Thermal Comfort Result: can contribute
 - Credit: Acoustic Performance Result: can contribute
- Innovation (IN)
 - Credit: Occupant Comfort Survey Result: can contribute

ENERGY CODES

- ANSI/ASHRAE/IES Standard 90.1 Energy Standard for Buildings Except Low-Rise Residential Buildings Result: meets requirementso International Green Construction Code® (IgCC®) Result: meets requirements
- International Energy Conservation Code® (IECC®) Result: meets requirements
- California Building Energy Efficiency Standards (Title 24) Result: meets requirements

BUILDING CODES

- International Mechanical Code® (IMC®) Result: meets requirements
- International Residential Code® (IRC®) Result: meets requirements

MILITARY

Qualified Products List of Products Qualified under Military Specification MIL-P-15280
 Plastic Material, Unicellular (Sheets and Tubes) - Result: listed